Errata

NFPA 10

Standard for Portable Fire Extinguishers

2002 Edition

Reference: 1.3.4
Errata No.: 10-02-1

The Committee on Portable Fire Extinguishers notes the following error in the 2002 edition of NFPA 10, *Standard for Portable Fire Extinguishers.*

1. In paragraph 1.3.4 revise 100 microsiemens/ cm to read:

1.00 microsiemens/cm

Issue Date: October 24, 2002

Copyright © 2002 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION